San Francisco • Sacramento • Las Vegas • Harrisburg

LaCroix Davis LLC

California State Board of Equalization
450 N Street, Sacramento, California

Mold Remediation – 14th Floor
Closure Report Addendum

Project No. 2372.02-572

Prepared for:
California Department of General Services
707 Third Street, 3-305
Sacramento, California 95605

Prepared by:
Chris Corpuz, MS, CIH, CAC
Senior Associate
LaCroix Davis LLC

Closure Report Date: December 8, 2009

Addendum Date: October 31, 2012

Please insert this Closure Report Addendum into the rear of the Floor 14 Closure Report

Building Environmental EHS Consulting
3685 Mt. Diablo Blvd., Ste. 210 • Lafayette, CA 94549 • p 925.299.1140 f 925.299.1185 • www.lacroixdavis.com

1.0 Introduction

On October 1, 2009, LaCroix Davis LLC (LCD) and the Department of General Services Mold Remediation Project Team completed the mold remediation activities initially scheduled for Floor 14 of the Board of Equalization (BOE) building located at 450 N Street, Sacramento, California. At the completion of these activities, a closure report for this floor was compiled by LCD to summarize key events of the project.

Subsequent to the completion of the closure report, a need for additional investigation and/or remediation activities was identified. Identified areas were subjected to sampling. Using a combination of surface tape lift and/or bulk samples, LCD tested stains on walls and other building materials to determine if the stains were indicative of mold growth. The sample locations are depicted in a revised Figure 2 attached to this addendum.

Any information not previously available and information documenting additional mold-related activities was compiled by LCD and included in this addendum.

2.0 Additional Activities

Additional mold-related activities performed on this floor after completion of the floor closure report include:

April 2010 Fire Sprinkler Riser Cabinet	Inspection, testing, and remediation.
November 2011 Rooms 1403 and 1406	Historic leaks from the sink in Breakroom 1402 and from above Room 1406 were discovered during vinyl composite tile replacement activities in Room 1405. Subsequently, Rooms 1403 and 1406 were inspected. No mold was found, and stained fireproofing was marked.



LaCroix Davis LLC

State of California
Department of General Services
(DGS No. 125828)
(AGMT. No. 3126150)
(LCD No. 2372.02-572)

Containment and Sample Locations (Oct 2012)

Board of Equalization Building, Mold Remediation
450 N Street, Sacramento, California

14th Floor

Figure 2

Daily Logs

LaCroix Davis LLC
Building & Environmental Forensics

PROJECT LOG

DATE: 4/9/10

LACROIX DAVIS LLC
3685 MT. DIABLO BLVD. SUITE 210
LAFAYETTE, CA 94549
TEL 925-299-1140 FAX 925-299-1185

Client	**Department of General Services (DGS)**	Contractor: **JLS Environmental**	Day ✓ Swing ✓ Weekend/Holiday ____
Project	**Board of Equalization (BOE)**	Location(s):	Floor 3 Floor 14 Floor 15 Floor 16
Building	**450 N Street, Sacramento CA**	Compound(s) of Concern	Mold ✓ / ACM / LBP
LCD Project # -Task	**2372.0 2 -572; SOW 5.0**	**Description:** Floor 3 containments	
LCD Project # -Task	**2372.0 3 -572; SOW 5.0** (separate log)	**Description:** Fire Riser Cabinets	
LCD Project # -Task	**2372.0 ____ -572; SOW ____**	**Description:** ____	

CONTAINMENT INFORMATION

1. Type of Containment: NPE ✓ Mini ____ Barrier Tape ____ Minor Procedures ____ HEPA ____
2. Type of Decon: Shower ____ 2-Stage ____ 1Stage ✓ Drop Sheet W/Vacuum ____ None ____
3. Manometer? Yes ✓ No ____ Strip Chart Record? Yes ✓ No ____ Adequate Pressure? Yes ✓ No ____ Comments Below.
4. Containment Entry Log? Yes ✓ No ____
5. Containment and Decon maintained in accordance with accepted practices and procedures? Yes ✓ No ____ Comment below.
6. Negative Air Machines and/or HEPA Vacuums Aerosol Challenge Tested? yes
7. Negative Air Exhaust Location: Window ____ Smoke Shaft ____ Stairs ✓ Unoccupied Space ✓
8. Site Security: 24 hr

SUMMARY OF ACTIVITIES

Mob/Demob FSR ✓ Prep FSR ✓ Removal FSR ✓ Waste Load Out FSR+C6 ✓ Detail Clean FSR+C6 ✓ Encapsulation FSR ✓ Clearance Testing ____ Tear Down ____

Visual Inspections: Pre-Abatement FSR ✓ Pre-Encapsulation FSR ✓ Pre-Clearance FSR ✓ Post Tear Down ____

Comments: Floor 3 containment C6 (Room 317) scraping floor and detail cleaning

Fire Riser Cabinets Floors 14, 15, 16 in SE Stairs

Waste Generated: Hazardous ____ Non-Hazardous/Construction Debris ✓ Adequately Wet ____ Waste Load-Out? ✓

Packaging: Single 6 Mil ____ Double 6 Mil ✓ Barrels ____ Boxes ____ Burrito Wrap ____ Other ____

Hazardous Waste Manifest? No Waste Characterization? ✓ Labels? No Comments: ____

Location of Dumpster: Floor 1 SW garage area

Additional Worker PPE: Disposable Suits ✓ Gloves ✓ (Respirator) Half Face ✓ Full Face ✓ PAPR ____

Contractor Worker Exposure Monitoring? No # Workers Sampled Ø

On-Site Visitors: 1. ____ 2. ____ 3. ____ 4. ____

LaCroix Davis Project LOG
Date: 4/9/10

PERSONAL EXPENSES:

Hotel: ✓ Per Diem: ✓ Travel: ✓ Destination: site & lab

FIELD SUPPLIES: PPE: Suits Day 2 / Swing? 6 to 9? Gloves (pairs) _____ Respirator filters: FSR Floor 3 Misc: _____

- Gary - can you track the # of suits for the FSR separate? thanks

LAB EXPENSES: Type/No. Samples collected: Tape _____ Bulk _____ Air _____

Laboratory Name: EML P&K

Notes

D 4/9 • JLS continues scraping mastic under cubicle partitions + general
meet w/ JLS ERamos to discuss tentative C6 schedule –
▸ cleaning under cubicles will be completed Friday 4/9
▸ detail cleaning will begin Friday 4/9 and conclude Saturday PM 4/
▸ clearance testing will occur Monday 4/12 AM
8 • meet w/ EML P&K to coordinate w/ lab analyst Brandon –
I will phone him 4/10 @ 8:00 AM to give him our plan for testing
saturday afternoon - based on when work concludes in FSR's
9 • meet w/ HTI to discuss stain floor at North perimeter wall and
probable water source (indoor plant/spill vs. outdoor leak)
enter containment and observe wall material removal at stain + floor scrap,
some rusting observed in wall cavity - source appears historic
leak beneath window - where precast panel meets metal at si
11 pk supplies at Grainger - Suits/resp. filters/resp wipes
13 JLS continues floor scrape
14 " " " " and detail
15: JLS checks all electrical covers to remove carpet
15: photo doc sealing cubicle feet and removal of
carpet remnants
15:30 Day shift concludes. Swing begins – detail clean
Swing - process planned entire shift + Saturday Day shift.

Signature _____ Date 4/9/10

LaCroix Davis
Building & Environmental Forensics

PROJECT LOG **DATE:** 4/9/10

LACROIX DAVIS LLC
3685 MT. DIABLO BLVD. SUITE 210
LAFAYETTE, CA 94549
TEL 925-299-1140 FAX 925-299-1185

Client	**Department of General Services (DGS)**	Contractor: **JLS Environmental**	Day____ Swing ✓ Weekend/Holiday____
Project	**Board of Equalization (BOE)**	Location(s):	Floor 16 Floor 15 Floor 14 Floor 3
Building	**450 N Street, Sacramento CA**	Compound(s) of Concern	Mold ACM LBP
LCD Project # -Task	**2372.0 3 -572; SOW 5.0**	**Description:** Fire Riser Cabinets	
LCD Project # -Task	**2372.0 2 -572; SOW 5.0** separate log	**Description:** Floor 3 Containment	
LCD Project # -Task	**2372.0____-572; SOW _____**	**Description:**_____	

CONTAINMENT INFORMATION

1. Type of Containment: NPE ✓ Mini ✓ Barrier Tape_____ Minor Procedures _____ HEPA _____
2. Type of Decon: Shower_____ 2-Stage_____ 1Stage ✓ Drop Sheet W/Vacuum_____ None_____
3. Manometer? Yes ✓ No____ Strip Chart Record? Yes ✓ No ____ Adequate Pressure? Yes ✓ No ____ Comments Below.
4. Containment Entry Log? Yes ✓ No_____
5. Containment and Decon maintained in accordance with accepted practices and procedures? Yes___ No ___ Comment below.
6. Negative Air Machines and/or HEPA Vacuums Aerosol Challenge Tested? _____
7. Negative Air Exhaust Location: Window_____ Smoke Shaft_____ Stairs_____ Unoccupied Space_____
8. Site Security: 24 hr

SUMMARY OF ACTIVITIES

Mob/Demob___ Prep___ Removal___ Waste Load Out___ Detail Clean___ Encapsulation___ Clearance Testing___ Tear Down___

Visual Inspections: Pre-Abatement____ Pre-Encapsulation____ Pre-Clearance_____ Post Tear Down_____

Comments:_____

Waste Generated: Hazardous ____Non-Hazardous/Construction Debris_____ Adequately Wet_____ Waste Load-Out? _____

Packaging: Single 6 Mil_____ Double 6 Mil _____ Barrels_____ Boxes_____ Burrito Wrap_____ Other_____

Hazardous Waste Manifest? _____ Waste Characterization? _____ Labels? _____ Comments: _____

Location of Dumpster: _____

Additional Worker PPE: Disposable Suits_____ Gloves _____ (Respirator) Half Face ____ Full Face ____ PAPR _____

Contractor Worker Exposure Monitoring? _____ # Workers Sampled _____

On-Site Visitors: 1._____ 2._____ 3._____ 4._____

PERSONAL EXPENSES:

Hotel: _____ Per Diem: _____ Travel: _____ Destination: _____

FIELD SUPPLIES: PPE: Suits 15 Gloves (pairs) 15 Respirator filters: _____ Misc: _____

LAB EXPENSES: Type/No. Samples collected: Tape _____ Bulk _____ Air _____

Laboratory Name: _____

Notes

145 & 146 West Stairway

18:10 GWB onsite

19:24 Crew begins to complete riser containments & HTI gl. bed

19:40 Inspected ~~and~~ and approved containments

20:45 Begin unspotting top section excav. scaffold, complete @ 21:15

21:21 Enter CG pictures, crew is final cleaning & about ½ way through

21:33 Begin initial inspecting lower cut out sections, lunch break at 20:30

22:48 Complete initial inspections of lower cutout sections.

0:10 Begin inspection of lower sections & inspection after encapsulation

1:30 inspection complete

1:30 GWB leave Site

Signature L Bayne

Date 4-9-10

LaCroix Davis LLC
Building & Environmental Forensics

PROJECT LOG **DATE:** 4/10/10

LACROIX DAVIS LLC
3685 MT. DIABLO BLVD. SUITE 210
LAFAYETTE, CA 94549
TEL 925-299-1140 FAX 925-299-1185

Client	**Department of General Services (DGS)**	Contractor: **JLS Environmental**	Day ✓ Swing ____ Weekend/Holiday ____
Project	**Board of Equalization (BOE)**	Location(s):	Floor 3 Floor 14 Floor 15 Floor 16
Building	**450 N Street, Sacramento CA**	Compound(s) of Concern	Mold ✓ / ACM / LBP
LCD Project # -Task	**2372.02 -572; SOW 5.0**	**Description:** Floor 3 Containment	
LCD Project # -Task	**2372.03 -572; SOW 5.0**	**Description:** Fire Riser Cabinets F14,15	
LCD Project # -Task	**2372.0 -572; SOW**	**Description:**	

CONTAINMENT INFORMATION

1. Type of Containment: NPE ✓ Mini ✓ Barrier Tape ____ Minor Procedures ____ HEPA ____
2. Type of Decon: Shower ____ 2-Stage ____ 1Stage ✓ Drop Sheet W/Vacuum ____ None ____
3. Manometer? Yes ✓ No ____ Strip Chart Record? Yes ✓ No ____ Adequate Pressure? Yes ✓ No ____ Comments Below.
4. Containment Entry Log? Yes ✓ No ____
5. Containment and Decon maintained in accordance with accepted practices and procedures? Yes ✓ No ____ Comment below.
6. Negative Air Machines and/or HEPA Vacuums Aerosol Challenge Tested? Yes
7. Negative Air Exhaust Location: Window ____ Smoke Shaft ____ Stairs ____ Unoccupied Space ✓
8. Site Security: 24 hr.

SUMMARY OF ACTIVITIES

Mob/Demob ✓ Prep ✓ C7, C8, Core Hall NW Removal ____ Waste Load Out ____ Detail Clean ✓ C6 Encapsulation ____ Clearance Testing ✓ FSR F14, 15 16 Tear Down ____

Visual Inspections: Pre-Abatement ✓ C7, C8, C9 Pre-Encapsulation ____ Pre-Clearance ✓ C6 Post Tear Down ____

Comments: ____

Waste Generated: Hazardous ____ Non-Hazardous/Construction Debris ____ Adequately Wet ____ Waste Load-Out? ____

N/A Packaging: Single 6 Mil ____ Double 6 Mil ____ Barrels ____ Boxes ____ Burrito Wrap ____ Other ____

Hazardous Waste Manifest? ____ Waste Characterization? ____ Labels? ____ Comments: ____

Location of Dumpster: ____

Additional Worker PPE: Disposable Suits ✓ Gloves ✓ (Respirator) Half Face ✓ Full Face ✓ PAPR ____

Contractor Worker Exposure Monitoring? Ø # Workers Sampled Ø

On-Site Visitors: 1. ____ 2. ____ 3. ____ 4. ____

LaCroix Davis Project LOG
Date: 4/10/10

PERSONAL EXPENSES:

Hotel: ✓ Per Diem: ✓ Travel: ✓ Destination: site + lab

FIELD SUPPLIES: PPE: Suits #8 Gloves (pairs) #8 Respirator filters: 2 Misc: _____

LAB EXPENSES: Type/No. Samples collected: Tape _____ Bulk _____ Air 8

Laboratory Name: EML P&K

Notes

7- Detail Cleaning continues Floor 3 C6 (Room 317) prep begins NW Core Hall at stairs door to restroom door <carpet with> then continues → to prep begins C7 (Room 312); C8 (Room 322 at column M23); C9 (rooms 324 and 325); and C10 (Room 303)

8:40 NW corehall containment completed and removal begins at 8:45

9:08 No Visible Mold Growth was observed on any of the removed sheet rock

9:15 Containment is cleaned to prepare for air testing

9:30 Final clearance performed in Fire sprinkler Riser Cabinets on Floors 14, 15, 16 with HTI WF and escort by JLS Exterior sample collected then visual inspection performed Floor 3 Room 317 (C6) containment

10:20 continue air clearance for FSRF 14, 15, 16

11:30 Sample COC and deliver to lab

13:00 inspect Room 303 containment

13:15 inspect Room 322 mini at column VMG behind column GB at base - JLS to determine additional fire wall removal

1405 inspect Room 321 containment - carpet typical ok to dispose and begin scraping floor mastic

14:15 Inspect 324/325 containment - wall materials VMG at base North where elevator shaft abuts. carpet typical Generate clearance memo for ~~elevator~~ Fire riser cabinets Floors 14, 15 and 16.

15:00 crews perform clean up of gross debris and some detail cleaning of surfaces.

15:30 meet w/ GS re: facilitating Monday schedule. ~~TEST 317 Corehall~~ detail cleaning 303, 312, 321, 324/325

Signature _____ Date 4/10/10

LaCroix Davis, LLC

LACROIX DAVIS LLC
3685 MT. DIABLO BLVD. SUITE 210
LAFAYETTE, CA 94549
TEL 925-299-1140 FAX 925-299-1185

PROJECT LOG **DATE: 11/18/11**

LCD REPS: TMI ;_____;_____

Client	**Department of General Services (DGS)**	Contractor: **JLS Environmental**	Day ___ Swing **X** Weekend/Holiday **X**
Project	**Board of Equalization (BOE)**	Location(s):	Floor **1** Floor____ Floors **8, 14**
Address	**450 N Street Sacramento, CA 95814**		Mold X ACM LBP Other - Benzene
LCD Project #	**2372.02-572; SOW** 5.0	**Description: Floor I FRP**	
LCD Project #	**2372.02-572; SOW** 5.0	**Description: VCT removal 8,14**	
LCD Project #	**2372.02-572; SOW** 4.0	**Description: Floor 1 Café column**	

CONTAINMENT INFORMATION

1. Floor Occupied ____X_____ Floor Vacant _____
2. Containments: a) **8A** b) **804** c) **14B** d) **1405** e) **F1 FRP #14** f) **F1 FRP #15**
3. Type of Containment: NPE **X** Mini_____ Barrier Tape_____ Minor Procedures _____ N/A _____
4. Type of Decon: Shower_____ 2-Stage_____ 1Stage **X** Drop Sheet W/Vacuum_____ None_____
5. Manometer: Yes **X** No____ Strip Chart Record: Yes **X** No ____ Adequate Pressure: Yes **X** No ____
6. Containment Entry Log: Yes **X** No_____
7. Containment and Decon maintained in accordance with accepted practices and procedures: Yes **X** No ___
8. HEPA Fans and Vacuums have current aerosol challenge test sticker: Yes **X** No ___
9. Negative Air Exhaust Location: Window_____ Shaft **a, b, c, d** Stairs_____ Interior **e, f** Exterior _____
10. Security: Owner **X** Contractor ____ Private____ 24 hour **X** Secure Building **X**

SUMMARY OF ACTIVITIES

Mob_**x**__ Prep_**x**___ Removal/Load Out_**X**_ Detail Clean_ Encapsulation___ Clearance Testing___ Tear Down___ DeMob____

Phase Completion Visual Inspection: Prep_____ Removal_____ Encapsulation_____ Clearance_____ Tear Down_____

Summary:_JLS MOBILIZES TO floor 1, 8 and 14

_____Meet w/ JLS GS and HTI LS to discuss work plan. JLS plans to bump room 139 to next Friday (holiday)

_____Prep begins floors 1 FRP containments #14 and #15 at SE corridor near 137 and at SE exit

_____Prep begins VCT (4 containments) 8A, 8B, 14B, 1405.

_____Prep completed. floor tile removal begins 14B 21:00 cove base inspection 2 sections w/rust screws 1st layer GB removed staining on 2nd layer. Floor tile removal continues. GB wall removed to 4' E at entry

_____ Prep complete

_____Removal completed Floor 1 FRP –

_____

_____ VCT removal begins . Summa cans set at midnight in place-shift complete at 2:30

_____

Waste: Non-Hazardous Construction Debris **X** Hazardous Waste ____ Hazardous Waste Manifest ____

Container: 6 Mil_____ Double 6 Mil ___**X**___ Barrel _____Drum_____ Box_____ Burrito Wrap_____ Labels _____ Other_____
Location of Dumpster: **Floor 1 SW Garage**
Additional Worker PPE: Disposable Suit **X** Gloves **X** Eye Protection **X** Steel Toe____ Hard Hat____ Chem Apron____
Respirator: Half Face **X** Full Face **X** PAPR _____Supplied Air_____
Contractor Worker Exposure Monitoring Yes_____ No___**X**___ # Workers Sampled _____
On-Site Visitors: 1. **M. Hoy** 2._____ 3._____ 4._____

PERSONAL EXPENSES:

Hotel: ___x__ Per Diem: x__Travel: ___x__ Destination: Air Toxics lab - Folsom
FIELD SUPPLIES: PPE: Suits ____.Gloves (pairs) ____Respirator filters: _____ Misc: _____

LAB EXPENSES: Type/No. Samples collected: Tape ___ Bulk ___ Air _____

Laboratory Name/Location:_EML P& K, W. Sacramento and Air Toxics, Folsom

Additional Notes

Signature_____ Date_**11/18/11**_____

DGS BOE Floor 1 FRP + Floor 8, 14 VCT

Note Title 11/18/2011

1800 JLS begins mob to floor 1 (2 locations at SE corridor)
Floor 8 VCT Rooms 8A & 804
Floor 14 VCT Rooms 14B & 1405
Floor 11 room not emptied - Floor 13 postponed to Next Friday

1830 inspect floor 1 Cafe column (beneath MAU) w/HTI + JLS
collect 1 sample - JLS paints small stain above ceiling
schedule cove base inspection for Sat. w/HTI in SE hall.

1930 prep continues all work areas

14 B



1405

VMG all lower walls
Remove 1' ↑ entire

remove

8A



No VMG at CB
22:50 removal VCT
trim base of GB ½"

N ↑
804



VMG w wall at S CB
rust screws other walls
remove 3" entire = No VMG

Floor 1 FRP Containment 14



Remove cove base
Remove Bumper Board 2x12
Remove GB 1' ↑

FRP Containment 15

Remove FRP
Remove GB (VMG)



00:00 Floor 1 detail cleaning continues #15, #14
GB removal continues #15

01:00 1405 VCT removal underway - completed 2:00
14B remove 1° layer GB at Entry E Wall to 4'
where VMG is visible on 2° layer GB at 2'

804 VCT removal and GB + trimmed base ½"
8A VCT removed

1405 waiting for GB removal (Sawzall)
in 14B - Next shift.
14B GB trim completed

Resume work at 7:00 AM
Floor 1 FRP #15 final cleaning
#14 to follow after 15 complete

LaCroix Davis, LLC

LACROIX DAVIS LLC
3685 MT. DIABLO BLVD. SUITE 210
LAFAYETTE, CA 94549
TEL 925-299-1140 FAX 925-299-1185

PROJECT LOG **DATE: 11/19/11**

LCD REPS: TMI ;_____;_____

Client	**Department of General Services (DGS)**	Contractor: **JLS Environmental**	Day X Swing_____ Weekend/Holiday_X__
Project	**Board of Equalization (BOE)**	Location(s):	Floor_1_Floor_14_ Floor_8___Floor____
			Mold X
			ACM LBP
			Other - Benzene
LCD Project #	**2372.02-572; SOW** 5.0	**Description: Floor I FRP #14**	
LCD Project #	**2372.02-572; SOW** 5.0	**Description: Floor 8, 14**	
LCD Project #	**2372.02-572; SOW** 5.0	**Description: Floor 1 FRP containments # 14**	

CONTAINMENT INFORMATION

1. Floor Occupied ____**X**_____ Floor Vacant _____
2. Containments: a) F1 frp14 b) F1 frp15 c) 8A d) 804 e) 14B f) 1405
3. Type of Containment: NPE **X** Mini_____ Barrier Tape_____ Minor Procedures _____ N/A _____
4. Type of Decon: Shower_____ 2-Stage_____ 1Stage **X** Drop Sheet W/Vacuum_____ None_____
5. Manometer: Yes **X** No____ Strip Chart Record: Yes **X** No ____ Adequate Pressure: Yes **X** No ____
6. Containment Entry Log: Yes **X** No_____
7. Containment and Decon maintained in accordance with accepted practices and procedures: Yes **X** No ___
8. HEPA Fans and Vacuums have current aerosol challenge test sticker: Yes **X** No ___
9. Negative Air Exhaust Location: Window_____ Shaft **VCT containments** Stairs_____ Interior **floor 1 containments** Exterior _____
10. Security: Owner **X** Contractor ____ Private____ 24 hour **X** Secure Building **X**

SUMMARY OF ACTIVITIES

Mob_ Prep Removal/Load Out **X** Detail Clean **X** Encapsulation___ Clearance Testing **X** F1 Tear Down DeMob

Phase Completion Visual Inspection: Prep_____ Removal **X** Encapsulation_____ Clearance_____ Tear Down_____

Summary: Floor 8, 14 – begin adhesive removal in all containments. Removal completed. Rough clean completed, final cleaning completed. Deta

completed. Schedule testing Sunday AM 6 w/ HTI & EML P&K

Floor 1 – perform clearance testing FRP #14, clearance complete, ok teardown

Waste: Non-Hazardous Construction Debris__X__ Hazardous Waste ____ Hazardous Waste Manifest ____

Container: 6 Mil_____ Double 6 Mil ___X_ Barrel _____Drum_____ Box_____ Burrito Wrap_____ Labels _____ Other_____

Location of Dumpster: __Floor 1 SW GARAGE

Additional Worker PPE: Disposable Suit__x__ Gloves _x___Eye Protection____ Steel Toe____ Hard Hat____ Chem Apron____ hearing_X

Respirator: Half Face __x_ Full Face ____ PAPR _____Supplied Air_____

Contractor Worker Exposure Monitoring Yes_x__ No_____ # Workers Sampled ____3_

On-Site Visitors: 1._____ 2._____ 3._____ 4._____

PERSONAL EXPENSES:

Hotel: x PerDiem: x Travel x destination: x site and lab

FIELD SUPPLIES: PPE: Suits _____ Gloves (pairs) _____Respirator filters: ___ Misc: _____

LAB EXPENSES: Type/No. Samples collected: Tape Bulk Air Other: VOC
Laboratory Name/Location: EML P&K W. Sacto , Air Toxics-Folsom

Additional Notes

__ J LS shift. Hours 7 to 1530 Crew 5+1

Signature/Date:_____**11/19/11**_____

DGS - BOE 11-19-11

Note Title 11/19/2011

7:00 JLS continues 14B GB wall trim
1405 removal of bottom 1' of GB all walls
804 & 8A prep for adhesive removal

7:30 meet w/ JLS E.R to discuss adhesive removal and request that only the adhesive be removed and as little disturbance as possible to the top surface of the concrete JLS will use smaller hand grinders to control scrape adhesive and try to only remove the adhesive

7

1405 inspect wall removal 1405
ID 2 small stains in wall cavity - collect 2 samples one in NW area common w/ 1404 and one in SE area common w/ 1403 - test FP Moisture content


N
1403
1404
1402
Break room
containment
1405
1406
removed GB !'
moisture 1.0
Sample FP
F14T01
F14B03
F14T02
stain ceiling tiles
previous replacement of GB
stain GB in wall cavity
stain FP at pipe hanger
directly above



adhesive removal will proceed Floor 8 then Floor 14
JLG anticipates ≈ 2 hours on 8

contact EMC P&K to set up analytical at ≈ 3

9:15 check adhesive removal floor 8



604A Floor surface was uneven and grinder removed most of top surface of concrete

604 similar uneven surface - grooved and pitted w/ adhesive in low spots that require disturb more concrete surface to remove all adhesive

10:00 collect bulk sample of FP 1406 NE prep to inspect cove base in 1406 NE and 1403 NW - areas adjacent to stains in wall cavity

discuss w/ KT + LS
set up painting FP stain w/ ER - JLS and
also cove base inspection in 1403 + 1406
for after Lunch

11:00 adhesive removal in 8A completed - gross
adhesive removal complete 8th

12:00 move grinders vacs to Floor 14 prep for adhesive removal
detail cleaning begins FLOOR 8

HTI - LS, JLS - GS on-site discuss progress & Floor 1 testing.
collect Floor 8 VOC samples - adhesive removal
completed

M Hoy call re: progress - site visit planned PM

12:30 prep for Covebase testing 1406 and 1403 w/ HTI & JLS
discuss w/ M. Hoy if pH testing should be performed Sunday AM. yes



Laboratory Reports

When quality and accuracy are critical.

9/26/2012

LaCroix Davis, LLC
3685 Mt. Diablo Blvd. Suite 210
Lafayette, CA 94549

To Whom It May Concern:

The following data qualifier is reported for all samples in which prior to the release, the replicate quality control sample was not completed:

"Analysis of replicate sample is delayed."

In all instances where this data qualifier was reported for LaCroix Davis, LLC projects "DGS-BOE", all replicate samples have since been analyzed and quality control reviews have been completed. All reported data should therefore be considered accurate and final.

Please feel free to contact me if you have any further questions in this regard.

Sincerely,

Dr. Kamashwaran Ramanathan
Laboratory Director

EMLab P&K

Report for:

Mr. Chris Corpuz, Mr. Ted Ice, Ms. Andrea Steinbach
LaCroix Davis, LLC
3685 Mt. Diablo Blvd.
Suite 210
Lafayette, CA 94549

Regarding: Project: DGS-BOE; Floors 14, 15, 16 FS Cabs
EML ID: 646538

Approved by:

Lab Manager
Malcolm Moody

Dates of Analysis:
Spore trap analysis: 04-10-2010

Service SOPs: Spore trap analysis (I100000)

For clarity, we report the number of significant digits as calculated; but, due to the nature of this type of biological data, the number of significant digits that is used for interpretation should generally be one or two. All samples were received in acceptable condition unless noted in the Report Comments portion in the body of the report. Due to the nature of the analyses performed, field blank corrections of results is not a standard practice. The results relate only to the items tested.

EMLab P&K ("the Company") shall have no liability to the client or the client's customer with respect to decisions or recommendations made, actions taken or courses of conduct implemented by either the client or the client's customer as a result of or based upon the Test Results. In no event shall the Company be liable to the client with respect to the Test Results except for the Company's own willful misconduct or gross negligence nor shall the Company be liable for incidental or consequential damages or lost profits or revenues to the fullest extent such liability may be disclaimed by law, even if the Company has been advised of the possibility of such damages, lost profits or lost revenues. In no event shall the Company's liability with respect to the Test Results exceed the amount paid to the Company by the client therefor.

Document Number: 200091 - Revision Number: 5

EMLab P&K
880 Riverside Parkway, West Sacramento, CA 95605
(866) 888-6653 Fax (650) 829-5852 www.emlab.com

Client: LaCroix Davis, LLC
C/O: Mr. Chris Corpuz, Mr. Ted Ice, Ms. Andrea Steinbach
Re: DGS-BOE; Floors 14, 15, 16 FS Cabs

Date of Sampling: 04-10-2010
Date of Receipt: 04-10-2010
Date of Report: 04-10-2010

SPORE TRAP REPORT: NON-VIABLE METHODOLOGY

Location:	2372-410-A01: Exterior North		2372-410-F16A02: Floor 16 Ambient SE Stairs		2372-410-F16A03: Floor 16 Containment FR Cabinet		2372-410-F15A04: Floor 15 Ambient SE Stairs	
Comments (see below)	None		None		None		None	
Lab ID-Version‡:	2864886-1		2864887-1		2864888-1		2864889-1	
	raw ct.	spores/m3	raw ct.	spores/m3	raw ct.	spores/m3	raw ct.	spores/m3
Alternaria	1	13						
Arthrinium								
Ascospores*								
Aureobasidium								
Basidiospores*	24	1,300						
Bipolaris/Drechslera group								
Botrytis								
Chaetomium								
Cladosporium	7	370	1	53	1	53		
Curvularia								
Epicoccum			1	13				
Fusarium								
Nigrospora								
Oidium								
Penicillium/Aspergillus types†	7	370						
Pithomyces								
Rusts*			1	13				
Smuts*, Periconia, Myxomycetes*	3	40	1	13	1	13	1	13
Stachybotrys								
Stemphylium								
Torula								
Ulocladium								
Background debris (1-4+)††	2+		3+		2+		2+	
Hyphal fragments/m3	40		13		< 13		< 13	
Pollen/m3	93		13		< 13		< 13	
Skin cells (1-4+)	< 1+		1+		< 1+		< 1+	
Sample volume (liters)	75		75		75		75	
§ TOTAL SPORES/m3		2,100		93		67		13

Comments:
* Most of these spore types are not seen with culturable methods (Andersen sampling), although some may appear as non-sporulating fungi. Most of the basidiospores are "mushroom" spores while the rusts and smuts are plant pathogens.
† The spores of *Aspergillus* and *Penicillium* (and others such as *Acremonium*, *Paecilomyces*) are small and round with very few distinguishing characteristics. They cannot be differentiated by non-viable sampling methods. Also, some species with very small spores are easily missed, and may be undercounted.
††Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher then reported. It is important to account for samples volumes when evaluating dust levels.
The Limit of Detection is the product of a raw count of 1 and 100 divided by the percent read. The analytical sensitivity (counts/m3) is the product of the Limit of Detection and 1000 divided by the sample volume.
‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".
§ Total Spores/m3 has been rounded to two significant figures to reflect analytical precision.

EMLab P&K
880 Riverside Parkway, West Sacramento, CA 95605
(866) 888-6653 Fax (650) 829-5852 www.emlab.com

Client: LaCroix Davis, LLC
C/O: Mr. Chris Corpuz, Mr. Ted Ice, Ms. Andrea Steinbach
Re: DGS-BOE; Floors 14, 15, 16 FS Cabs

Date of Sampling: 04-10-2010
Date of Receipt: 04-10-2010
Date of Report: 04-10-2010

SPORE TRAP REPORT: NON-VIABLE METHODOLOGY

Location:	2372-410-F15A05: Floor 15 Containment FR Cabinet		2372-410-F14A06: Floor 14 Ambient SE Stairs		2372-410-F14A07: Floor 14 Containment FR Cabinet		2372-410-A08: Exterior SW	
Comments (see below)	None		None		A		None	
Lab ID-Version‡:	2864890-1		2864891-1		2864892-1		2864893-1	
	raw ct.	spores/m3	raw ct.	spores/m3	raw ct.	spores/m3	raw ct.	spores/m3
Alternaria								
Arthrinium								
Ascospores*								
Aureobasidium								
Basidiospores*							45	2,400
Bipolaris/Drechslera group								
Botrytis								
Chaetomium								
Cladosporium	1	53					8	430
Curvularia								
Epicoccum								
Fusarium								
Nigrospora								
Oidium							1	13
Penicillium/Aspergillus types†							1	53
Pithomyces								
Rusts*			1	13			1	13
Smuts*, Periconia, Myxomycetes*							70	930
Stachybotrys								
Stemphylium								
Torula								
Ulocladium								
Background debris (1-4+)††	2+		3+		3+		2+	
Hyphal fragments/m3	< 13		< 13		< 13		53	
Pollen/m3	< 13		< 13		13		330	
Skin cells (1-4+)	< 1+		< 1+		1+		< 1+	
Sample volume (liters)	75		75		75		75	
§ TOTAL SPORES/m3		53		13		< 13		3,800

Comments: A) No spores detected.
* Most of these spore types are not seen with culturable methods (Andersen sampling), although some may appear as non-sporulating fungi. Most of the basidiospores are "mushroom" spores while the rusts and smuts are plant pathogens.
† The spores of *Aspergillus* and *Penicillium* (and others such as *Acremonium*, *Paecilomyces*) are small and round with very few distinguishing characteristics. They cannot be differentiated by non-viable sampling methods. Also, some species with very small spores are easily missed, and may be undercounted.
††Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher then reported. It is important to account for samples volumes when evaluating dust levels.
The Limit of Detection is the product of a raw count of 1 and 100 divided by the percent read. The analytical sensitivity (counts/m3) is the product of the Limit of Detection and 1000 divided by the sample volume.
‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".
§ Total Spores/m3 has been rounded to two significant figures to reflect analytical precision.

EMLab P&K
880 Riverside Parkway, West Sacramento, CA 95605
(866) 888-6653 Fax (650) 829-5852 www.emlab.com

Client: LaCroix Davis, LLC
C/O: Mr. Chris Corpuz, Mr. Ted Ice, Ms. Andrea Steinbach
Re: DGS-BOE; Floors 14, 15, 16 FS Cabs

Date of Sampling: 04-10-2010
Date of Receipt: 04-10-2010
Date of Report: 04-10-2010

MoldRANGE™: Extended Outdoor Comparison

Outdoor Location: 2372-410-A01, Exterior North

Fungi Identified	Outdoor data	Typical Outdoor Data by Date† Month: April				Typical Outdoor Data by Location‡ State: CA			
	spores/m3	low	med	high	freq %	low	med	high	freq %
Generally able to grow indoors*									
Alternaria	13	7	27	220	43	7	27	230	56
Bipolaris/Drechslera group	-	7	13	140	12	7	13	130	13
Chaetomium	-	7	13	120	12	7	13	120	20
Cladosporium	370	27	310	4,200	91	53	630	7,100	97
Curvularia	-	7	13	240	7	7	13	230	7
Nigrospora	-	7	13	95	8	7	13	180	8
Penicillium/Aspergillus types	370	14	160	1,500	72	33	210	2,500	85
Stachybotrys	-	7	13	310	3	7	13	250	5
Torula	-	7	13	170	11	7	13	150	12
Seldom found growing indoors**									
Ascospores	-	13	110	2,900	74	13	110	2,000	70
Basidiospores	1,300	13	200	5,500	88	13	210	8,000	93
Oidium	-	7	20	240	21	7	13	190	20
Rusts	-	7	20	250	22	7	13	270	28
Smuts, Periconia, Myxomycetes	40	7	33	440	60	8	40	510	69
§ TOTAL SPORES/m3	2,100								

† The Typical Outdoor Data by Date represents the typical outdoor spore levels across North America for the month indicated. The last column represents the frequency of occurrence. The low, medium, and high values represent the 2.5, 50, and 97.5 percentile values of the spore type when it is detected. For example, if the frequency of occurrence is 63% and the low value is 53, it would mean that the given spore type is detected 63% of the time and, when detected, 2.5% of the time it is present in levels above the detection limit and below 53 spores/m3. These values are updated periodically, and if enough data is not available to make a statistically meaningful assessment, it is indicated with a dash.

‡ The Typical Outdoor Data by Location represents the typical outdoor spore levels for the region indicated for the entire year. As with the Typical Outdoor Data by Date, the four columns represent the frequency of occurrence and the typical low, medium, and high concentration values for the spore type indicated. These values are updated periodically, and if enough data is not available to make a statistically meaningful assessment, it is indicated with a dash.

§ Total Spores/m3 has been rounded to two significant figures to reflect analytical precision.

*The spores in this category are generally capable of growing on wet building materials in addition to growing outdoors. Building related growth is dependent upon the fungal type, moisture level, type of material, and other factors. *Cladosporium* is one of the predominant spore types worldwide and is frequently present in high numbers. *Penicillium/Aspergillus* species colonize both outdoor and indoor wet surfaces rapidly and are very easily dispersed. Other genera are usually present in lesser numbers.

**These fungi are generally not found growing on wet building materials. For example, the rusts and smuts are obligate plant pathogens. However, in each group there are notable exceptions. For example, agents of wood decay are members of the basidiomycetes and high counts of a single morphological type of basidiospore on an inside sample should be considered significant.

Interpretation of the data contained in this report is left to the client or the persons who conducted the field work. This report is provided for informational and comparative purposes only and should not be relied upon for any other purpose. "Typical outdoor data" are based on the results of the analysis of samples delivered to and analyzed by EMLab P&K and assumptions regarding the origins of those samples. Sampling techniques, contaminants infecting samples, unrepresentative samples and other similar or dissimilar factors may affect these results. In addition, EMLab P&K may not have received and tested a representative number of samples for every region or time period. EMLab P&K hereby disclaims any liability for any and all direct, indirect, punitive, incidental, special or consequential damages arising out of the use or interpretation of the data contained in, or any actions taken or omitted in reliance upon, this report.

EMLab P&K
880 Riverside Parkway, West Sacramento, CA 95605
(866) 888-6653 Fax (650) 829-5852 www.emlab.com

Client: LaCroix Davis, LLC
C/O: Mr. Chris Corpuz, Mr. Ted Ice, Ms. Andrea Steinbach
Re: DGS-BOE; Floors 14, 15, 16 FS Cabs

Date of Sampling: 04-10-2010
Date of Receipt: 04-10-2010
Date of Report: 04-10-2010

MoldRANGE™: Extended Outdoor Comparison

Outdoor Location: 2372-410-A08, Exterior SW

Fungi Identified	Outdoor data	Typical Outdoor Data by Date† Month: April				Typical Outdoor Data by Location‡ State: CA			
	spores/m3	low	med	high	freq %	low	med	high	freq %
Generally able to grow indoors*									
Alternaria	-	7	27	220	43	7	27	230	56
Bipolaris/Drechslera group	-	7	13	140	12	7	13	130	13
Chaetomium	-	7	13	120	12	7	13	120	20
Cladosporium	430	27	310	4,200	91	53	630	7,100	97
Curvularia	-	7	13	240	7	7	13	230	7
Nigrospora	-	7	13	95	8	7	13	180	8
Penicillium/Aspergillus types	53	14	160	1,500	72	33	210	2,500	85
Stachybotrys	-	7	13	310	3	7	13	250	5
Torula	-	7	13	170	11	7	13	150	12
Seldom found growing indoors**									
Ascospores	-	13	110	2,900	74	13	110	2,000	70
Basidiospores	2,400	13	200	5,500	88	13	210	8,000	93
Oidium	13	7	20	240	21	7	13	190	20
Rusts	13	7	20	250	22	7	13	270	28
Smuts, Periconia, Myxomycetes	930	7	33	440	60	8	40	510	69
§ TOTAL SPORES/m3	3,800								

† The Typical Outdoor Data by Date represents the typical outdoor spore levels across North America for the month indicated. The last column represents the frequency of occurrence. The low, medium, and high values represent the 2.5, 50, and 97.5 percentile values of the spore type when it is detected. For example, if the frequency of occurrence is 63% and the low value is 53, it would mean that the given spore type is detected 63% of the time and, when detected, 2.5% of the time it is present in levels above the detection limit and below 53 spores/m3. These values are updated periodically, and if enough data is not available to make a statistically meaningful assessment, it is indicated with a dash.

‡ The Typical Outdoor Data by Location represents the typical outdoor spore levels for the region indicated for the entire year. As with the Typical Outdoor Data by Date, the four columns represent the frequency of occurrence and the typical low, medium, and high concentration values for the spore type indicated. These values are updated periodically, and if enough data is not available to make a statistically meaningful assessment, it is indicated with a dash.

§ Total Spores/m3 has been rounded to two significant figures to reflect analytical precision.

*The spores in this category are generally capable of growing on wet building materials in addition to growing outdoors. Building related growth is dependent upon the fungal type, moisture level, type of material, and other factors. *Cladosporium* is one of the predominant spore types worldwide and is frequently present in high numbers. *Penicillium/Aspergillus* species colonize both outdoor and indoor wet surfaces rapidly and are very easily dispersed. Other genera are usually present in lesser numbers.

**These fungi are generally not found growing on wet building materials. For example, the rusts and smuts are obligate plant pathogens. However, in each group there are notable exceptions. For example, agents of wood decay are members of the basidiomycetes and high counts of a single morphological type of basidiospore on an inside sample should be considered significant.

Interpretation of the data contained in this report is left to the client or the persons who conducted the field work. This report is provided for informational and comparative purposes only and should not be relied upon for any other purpose. "Typical outdoor data" are based on the results of the analysis of samples delivered to and analyzed by EMLab P&K and assumptions regarding the origins of those samples. Sampling techniques, contaminants infecting samples, unrepresentative samples and other similar or dissimilar factors may affect these results. In addition, EMLab P&K may not have received and tested a representative number of samples for every region or time period. EMLab P&K hereby disclaims any liability for any and all direct, indirect, punitive, incidental, special or consequential damages arising out of the use or interpretation of the data contained in, or any actions taken or omitted in reliance upon, this report.

CHAIN OF CUSTODY

EMLab P&K

www.EMLabPK.com

Cherry Hill, NJ: 1936 Olney Avenue, Cherry Hill, NJ 08003 * (866) 871-1984
Phoenix, AZ: 1501 West Knudsen Drive, Phoenix, AZ 85027 * (800) 651-4802
San Bruno, CA: 1150 Bayhill Drive, #100, San Bruno, CA 94066 * (866) 888-6653

WEATHER	Fog	Rain	Snow	Wind	Clear
None	X	XX			
Light				X	
Moderate					
Heavy					

LEVEL

000646538

CONTACT INFORMATION

Company: LaCroix Davis, LLC
Address: 3685 Mt. Diablo Blvd. Ste 210
Contact: CCarp02; T.Ices; A.Stembach
Special Instructions: Lafayette, CA 94549
Phone:

PROJECT INFORMATION

Project ID: DGS - BOE
Project Desc.: Floors 14,15,16 FS Cabs
Project Zip Code:
Sampling Date & Time: 4/10/10 9:30
PO Number: 2372.03 - 572

TURNAROUND TIME CODES - (TAT)

STD - Standard (DEFAULT)
ND - Next Business Day
SD - Same Business Day Rush
WH - Weekend/Holiday

Rushes received after 2pm or on weekends will be considered received the next business day. Please alert us in advance of weekend analysis needs.

REQUESTED SERVICES (✓ Box)

Non-Culturable: Spore Trap; Tape Swab Bulk
Culturable: BioCassette™, Andersen, SAS, Swab, Water, Bulk, Dust, Soil, Contact Plate
Other Requests

Sample ID	Description	Sample Type (Below)	TAT (Above)	Total Volume/Area (as applicable)	Notes (Time sprgn, Temp, RH, etc.)	Fungi - Spore Trap Analysis	Spore Trap Analysis - Other particles	Direct Microscopic Exam (Qualitative)	Quantitative Spore Count, Direct Exam	1-Media Surface Fungi (Genus ID + Asp. spp.)	2-Media Surface Fungi (Genus ID + Asp. spp.)	3-Media Surface Fungi (Genus ID + Asp. spp.)	Culturable Air Fungi (Genus ID + Asp. spp.)	Grain Stain and Counts (Culturable Air and Surface Bacteria)	Legionella culture	Total Coliform, E.coli (Presence/Absence)	Membrane Filtration (Please specify organism)	MPN Bacteria (Please specify organism)	QuantiTray - Sewage Screen	Asbestos Analysis - PCM Airborne Fiber Count (NIOSH 7400)	Asbestos Analysis - PLM (EPA method 600/R-93-116)	PCR (please specify test)
2372 410-A01	Exterior North	ST	WH	75	9:30	X																
2372 410-F16A02	Floor 16 Ambient SE Stairs	ST	WH	75		X																
2372 410-F16A03	Floor 16 Containment FR Cabinet	ST	WH	75		X																
2372 410-F15A04	Floor 15 Ambient SE Stairs	ST	WH	75		X																
2372 410-F15A05	Floor 15 Containment FR Cabinet	ST	WH	75		X																
2372 410-F14A06	Floor 14 Ambient SE Stairs	ST	WH	75		X																
2372 410-F14A07	Floor 14 Containment FR Cabinet	ST	WH	75		X																
2372 410-A08	Exterior SW	ST	WH	75	11:30	X																

SAMPLE TYPE CODES

BC - BioCassette™	ST - Spore Trap: Zefon, Allergenco, Burkard...	T - Tape	D - Dust
A1S - Andersen		SW - Swab	SO - Soil
SAS - Surface Air Sampler	P - Potable Water	B - Bulk	
CP - Contact Plate	NP - Non-Potable Water	O - Other:	

RELINQUISHED BY	DATE & TIME
Dhesmola	4/10/10 1200

RECEIVED BY	DATE & TIME
Brandon Bedan	4/10/10 @ 1145

4/10/10 F14 F15 F16 Fire Sprinkler Riser Cabinets AIR

EMLab P&K

Report for:

Mr. Chris Corpuz, Mr. Ted Ice, Ms. Andrea Steinbach
LaCroix Davis, LLC
3685 Mt. Diablo Blvd.
Suite 210
Lafayette, CA 94549

Regarding: Project: DGS-BOE; Floor 14 VCT
EML ID: 858820

Approved by:

Lab Manager
Malcolm Moody

Dates of Analysis:
Direct microscopic exam (Qualitative): 11-22-2011

Service SOPs: Direct microscopic exam (Qualitative) (I100005)

All samples were received in acceptable condition unless noted in the Report Comments portion in the body of the report. Due to the nature of the analyses performed, field blank correction of results is not applied. The results relate only to the items tested.

EMLab P&K ("the Company") shall have no liability to the client or the client's customer with respect to decisions or recommendations made, actions taken or courses of conduct implemented by either the client or the client's customer as a result of or based upon the Test Results. In no event shall the Company be liable to the client with respect to the Test Results except for the Company's own willful misconduct or gross negligence nor shall the Company be liable for incidental or consequential damages or lost profits or revenues to the fullest extent such liability may be disclaimed by law, even if the Company has been advised of the possibility of such damages, lost profits or lost revenues. In no event shall the Company's liability with respect to the Test Results exceed the amount paid to the Company by the client therefor.

Document Number: 200091 - Revision Number: 5

EMLab P&K
880 Riverside Parkway, West Sacramento, CA 95605
(866) 888-6653 Fax (650) 829-5852 www.emlab.com

Client: LaCroix Davis, LLC
C/O: Mr. Chris Corpuz, Mr. Ted Ice, Ms. Andrea Steinbach
Re: DGS-BOE; Floor 14 VCT

Date of Sampling: 11-19-2011
Date of Receipt: 11-22-2011
Date of Report: 11-23-2011

DIRECT MICROSCOPIC EXAMINATION REPORT

(Wet Mount)

Background Debris and/or Description	Miscellaneous Spores Present*	MOLD GROWTH: Molds seen with underlying mycelial and/or sporulating structures†	Other Comments††	General Impression
Lab ID-Version‡: 3810068-1: Bulk sample 2372-1119-F1406-B03: NE-NP AC				
Miscellaneous debris	Very few	None	None	Normal trapping
Lab ID-Version: 3810069-1: Tape sample 2372-1119-F1405-T01: NW Wall Cavity GB Stain				
Heavy	Very few	None	None	Normal trapping
Lab ID-Version: 3810070-1: Tape sample 2372-1119-F1405-T02: SE Wall Cavity GB Stain				
Heavy	Very few	None	None	Normal trapping

* Indicative of normal conditions, i.e. seen on surfaces everywhere. Includes basidiospores (mushroom spores), myxomycetes, plant pathogens such as ascospores, rusts and smuts, and a mix of saprophytic genera with no particular spore type predominating. Distribution of spore types seen mirrors that usually seen outdoors.

† Quantities of molds seen growing are listed in the MOLD GROWTH column and are graded 1+ to 4+, with 4+ denoting the highest numbers.

†† Some comments may refer to the following: Most surfaces collect a mix of spores which are normally present in the outdoor environment. At times it is possible to note a skewing of the distribution of spore types, and also to note "marker" genera which may indicate indoor mold growth. Marker genera are those spore types which are present normally in very small numbers, but which multiply indoors when conditions are favorable for growth.

‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

CHAIN OF CUSTODY

EMLab P&K

www.EMLabPK.com

Cherry Hill, NJ: 1936 Olney Avenue, Cherry Hill, NJ 08003 * (866) 871-1984
Phoenix, AZ: 1501 West Knudsen Drive, Phoenix, AZ 85027 * (800) 651-4802
San Bruno, CA: 1150 Bayhill Drive, #300, San Bruno, CA 94066 * (866) 888-6653

WEATHER	Fog	Rain	Snow	Wind	Clear
LEVEL None					
Light					
Moderate					
Heavy					4

000858820

CONTACT INFORMATION

Company: LaCroix Davis, LLC
Contact: C. Compuz; T. Ice; A. Steinbeck
Phone: 925-299-1140

Address: 3665 Mt. Diablo Blvd. Ste 210 Lafayette, CA 94549
Special Instructions: email contacts

PROJECT INFORMATION

Project ID: DGS-BOE
Project Desc: Floor 8 & 14 VCT
Project Zip Code:
Sampling Date & Time: 11/19/11
PO Number: 2372.02-512

TURN AROUND TIME CODES - (TAT)

STD Standard (DEFAULT)
ND - Next Business Day
SD - Same Business Day Rush
WH - Weekend/Holiday

Rushes received after 2pm or on weekends, will be considered received the next business day. Please alert us in advance of weekend analysis needs.

REQUESTED SERVICES (✓)

Non-Culturable: Spore Trap; Tape Swab Bulk
Culturable: BioCassette™ Andersen, SAS, Swab, Water, Bulk, Dust, Soil, Contact Plate
Other Requested

Sample ID	Description	Sample Type (Below)	TAT (Above)	Total Volume/Area (as applicable)	NOTES (Time of day, Temp, RH, etc.)	Fungi - Spore Trap Analysis	Spore Trap Analysis - Other particles	Direct Microscopic Exam (Qualitative)	Quantitative Spore Count Direct Exam	1-Media Surface Fungi (Genus ID + Asp. spp.)	2-Media Surface Fungi (Genus ID + Asp. spp.)	3-Media Surface Fungi (Genus ID + Asp. spp.)	Culturable Air Fungi (Genus ID + Asp. spp.)	Gram Stain and Counts (Culturable Air and Surface Bacteria)	Legionella culture	Total Coliform, E.coli (Presence/Absence)	Membrane Filtration (Please specify organism)	MPN Bacteria (Please specify organism)	Quest Tray - Sewage Screen	Asbestos Analysis - PCM Airborne Fiber Count (NIOSH 7400)	Asbestos Analysis - PLM (EPA method 600/R-93-116)	PCR (please specify test)
2372-1119-F1406 B03	NE-FP ac	B	STD	—	6" Ø at pipe hanger			X														
2372-1119-F1405 T01	NW wall cavity GB stain	T	STD	—	2" thin line			X														
2372-1119-F1405 T02	SE Wall Cavity GB stain	T	STD	—	triangle shape			X														

SAMPLE TYPE CODES

BC - BioCassette™	ST - Spore Trap: Zefon, Allergenco, Burkard...	T - Tape	D - Dust
AIS - Andersen		SW - Swab	SO - Soil
SAS - Surface Air Sampler	P - Potable Water	B - Bulk	
CP - Contact Plate	NP - Non-Potable Water	O - Other:	

RELINQUISHED BY	DATE & TIME
[signature]	11/19/11

RECEIVED BY	DATE & TIME
[signature]	11/22/11 10AM

11/19/11 Floor 14